

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI012621
DATE: 04/20/2015
CERTIFICATION PROGRAM: Structural
COMPANY: Bevel King
CODE: B-1168-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|---|
| Bevel King Door and Glass Company 4400 Commerce Circle SW Atlanta, GA 30336 | "Wood Double Entry Door" Glazed Wood In-Swing Double Side-Hinged Door Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1880mm(74") H-2464mm(97") Panel: W-940mm(37") H-2438mm(96") DLO: W-533mm(21") H-1676mm(66") |

| SPECIFICATION | PRODUCT RATING |
|----------------------------------|------------------------------------|
| ASTM E283-04/E330-02(10)/E547-00 | Design Pressure: ±2400 Pa (50 psf) |

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3986-01
Expiration Date: January 31, 2019

Administrator's Signature:  _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122